ACOUSTICS2008/3499 Reproducibity and life duration assessment of cMUT transducers

Cyril Meynier^a, Dominique Certon^b, Franck Teston^b and Guillaume Ferin^a

^aVermon SA, 180 rue Général Renault, 37000 Tours, France

^bLab. LUSSI Inserm U930 CNRS FRE 2448 Univ. François Rabelais, 10, Boulevard Tonnellé, 37032 Tours,

France

Cmut-based transducers are often expected to be superior in terms of reproducibility to piezoelectric transducers due to the use of microelectronic technology instead of more traditional machining techniques.

During the conventional (sacrificial-layer based) production process of cmut transducers, various process steps can display inhomogenities and uncertainty in flow rate, temperature profile, stochiometry, or other aspects, resulting in variations in layers thicknesses, gap height, and material properties, each having an impact on transducer performances.

In this study, we choose to use impedance measurement technique as evaluation tool for the stability of the properties of cmut transducers. A large number of cMUT transducers with the same design, were characterized, allowing to compare their properties from wafer to wafer, and according to their position of origin in the wafer.

The resistance of cmut transducers to temperature cycling was also investigated, using impedance and optical measurements control before and after a 3-days $+60/-20^{\circ}$ c test.

The reliability was tested under a long-duration electroacoustic measurement, where a cMUT transducer was submitted to periodic large amplitude excitation, and its pulse-echo response recorded for several hours.